

Sent 4:25 pm

# ASH GROVE CEMENT COMPANY



"WESTERN REGION"

**Date:** September 2, 1994

**To:** Mr. Fred Austin, PSAPCA  
Mr. Tom Hudson, PSAPCA

**From:** Gerald J. Brown

**Subject:** Condition Report  
Kiln Start up  
Fax Notification

**Copy:** Ed Pierce  
Nate Fernow

---

This report is intended as a follow-up to our faxed notification regarding the unplanned shutdown of the kiln on September 1, 1994

The plug which forced the shutdown has been removed from the feed pipe. We are presently replacing damaged refractory in the kiln and will begin preheating as soon as repairs permit. Preheating is expected to commence late night 9/2 or early Saturday 9/3 with kiln start up beginning 24 hours later.

During the latter stages of preheat, some visible emissions from the kiln seals are expected.

Please call if you have any questions.